



The association of electrical equipment  
and medical imaging manufacturers  
[www.nema.org](http://www.nema.org)

National Electrical Manufacturers Association

March 27, 2023

Mr. Jeremy Dommu  
U.S. Department of Energy  
Office of Energy Efficiency and Renewable Energy  
Building Technologies Office, EE-5B  
1000 Independence Avenue SW  
Washington, DC 20585-0121

Re: Energy Conservation Program: Energy Conservation Standards for Distribution Transformers, docket  
EERE-2019-BT-STD-0018

Submitted electronically to [DistributionTransformers2019STD0018@ee.doe.gov](mailto:DistributionTransformers2019STD0018@ee.doe.gov)

Dear Mr. Dommu,

The National Electrical Manufacturers Association (NEMA) represents nearly 325 electrical equipment and medical imaging manufacturers that make safe, reliable, and efficient products and systems serving building systems, building infrastructure, lighting systems, industrial products and systems, utility products and systems, transportation systems, and medical imaging. Our combined industries account for 370,000 American jobs in more than 6,100 facilities covering every state. These industries produce \$124 billion in shipments and \$42 billion in exports of electrical equipment and medical imaging technologies per year.

Members of the NEMA Transformer Products Section share the Department of Energy's (DOE) and the greater efficiency community's interest in reducing distribution transformer losses across the entire U.S. electric grid, as well as within commercial and industrial buildings and other applications. Indeed, NEMA has worked for years developing more efficient, application-specific distribution transformer products to ensure more generation capacity is available to meet demand.

We also support the DOE's commitment to grid modernization, electrification, clean energy development, and a robust U.S. clean energy manufacturing sector.

However, NEMA anticipates that the proposed *Energy Conservation Program: Energy Conservation Standards for Distribution Transformers* Rulemaking (Rule) will, in fact, act as a barrier to these shared priorities. As we explain in detail below, the Rule would contribute to and exacerbate well-known production lead times for distribution transformers, slowing significantly progress toward electrification. It would do nothing to ensure sufficient domestic supply chain inputs for more product efficiency, leaving concerns about U.S. manufacturing capacity unaddressed.

Real questions remain regarding just how energy efficient distribution transformers will become if manufactured to the Rule's new requirements. Particularly, NEMA expresses concerns about these products' implied efficiencies when implemented under actual operating conditions, particularly transformer loading which impacts energy efficiency, as well as other variable changes as the economy continues to electrify.

Furthermore, NEMA is acutely aware of the Administration's concern regarding the need to increase domestic distribution transformer production as evidenced by the inclusion of transformers in President Biden's June 6, 2022 invocation of the Defense Production Act (DPA) for clean energy technologies.

While our comments below highlight the many serious problems with the proposed rule, NEMA stands ready to work with DOE, other Departments, and Agencies to create the conditions in which energy conservation standards for distribution transformers can be achieved in ways that increase domestic manufacturing capacity, save energy, enhance grid reliability, boost electrification, and foster clean energy.

As proposed, the Rule seeks to achieve greater levels of energy efficiency in distribution transformers by requiring that its core components be manufactured using amorphous steel. On paper, this proposal can be achieved under controlled and assumed situations; however, in practice this proposal is resoundingly unachievable mainly due to the absence of an existing supply chain needed to meet the Rule's expectations at scale and assumptions about the energy efficiency performance of amorphous steel cores that are likely unachievable in application. The proposal completely underestimates or simply ignores the market, political, and regulatory variables necessary to stand up a secure and resilient domestic supply chain for critical infrastructure materials and components.

Further, he noted that “*more resilient supply chains are secure and diverse—facilitating greater domestic production, a range of supply, built-in redundancies*”. As proposed, the Rule focuses solely on a single element of this list of necessities – domestic production – while downplaying or disregarding others. NEMA members acknowledge and support the need to increase domestic production and manufacturing of goods, and government plays an important role in incentivizing this type of investment. However, mandating through regulation a single variable at the expense of others among a supply chain creates a dangerous imbalance.

Distribution transformer production relies on a diverse supply chain to source parts and components to meet the American market demand for such products. Transformer cores made from grain-oriented electrical steel (GOES) are both manufactured in-house by NEMA members and purchased from third party sources. However, domestic transformer electromanufacturers do not currently have the ability to

<sup>2</sup> <https://www.whitehouse.gov/briefing-room/statements-releases/2022/06/06/fact-sheet-president-biden-takes-bold-executive-action-to-spur-domestic-clean-energy-manufacturing/>

produce amorphous steel cores internally, requiring them to be purchased exclusively from third parties. Through its proposed Rule, the Department would require every manufacturer to shift their diverse and reliable supply chain and internal capabilities and rely on external vendors to supply this critical component unless significant capital expenditures were implemented. Mandating single-sourcing of materials not only creates severe risks and uncertainties in a product's order cycle – which in turn imposes higher costs on electric utilities, homebuilders, and customers – it goes against the Administration's own policy goal of supply chain diversification and built-in redundancy.

In the case of amorphous steel cores, we know of just a single domestic manufacturer currently offering these components. To our knowledge, this manufacturer is the only company which has made the investment necessary to bring such a product to market, on any scale. Furthermore, this one company does not appear to have any market competition. Due in part to capital intensive start-up costs and lengthy permitting processes associated with the domestic manufacturing of amorphous steel cores, new capacity to increase production quickly to meet current demand, let alone increased future demand, is unlikely in the foreseeable future. There are no companies standing up new amorphous steel production lines, nor are there any federal funding initiatives aimed at expanding domestically amorphous steel manufacturing.

The proposed Rule has the potential to accentuate an already monopolistic situation in the distribution transformer market. An unchecked, federally endorsed monopoly on critical manufacturing material will also work against the Administration's grid modernization and electrification goals by dramatically increasing costs and lead times. Further, we believe the Rule may run afoul of anti-trust statutes.

In addition to how the Rule would severely impact the production of distribution transformers, the requirement of amorphous steel cores also creates downstream logistical issues, which in turn enhance risks to grid resiliency and reliability. First, the physical properties of transformers which utilize amorphous core are often considerably larger in size and much heavier relative to a competing non-amorphous core. This will require manufacturers to reconfigure their assembly processes, including time to retrain electricians to match transformer coils to calibrate with the properties of the new steel. The hand-made coils will require considerably more steel, adding weight to enable the performance required by the proposed Rule. Further, the steel tanks which house both the coil and cores will need to be reconfigured to match these new dimensions.

Second, the transportation, delivery, and implementation of these new products will also be impacted. The increased size means fewer units per truck, thus larger and heavier equipment will require more trucks to move such equipment to their installation locations. Larger and heavier means that for pole-mounted transformers, new poles to support the weight will have to be sourced; for pad-mounted transformers, thicker and larger concrete pads will have to be poured. Larger and heavier also means bigger boom cranes necessary to lift such equipment will need to be procured. When taken together, the affiliated emissions that will come from amorphous core transformers – including from excess tailpipe emissions due to increased trucking to industrial carbon from greater concrete usage – could, ironically, counter many of the efficiency gains the Rule is attempting to achieve.

NEMA has been a long-time advocate for product efficiency; however, the timing and intent of the proposed Rule would severely undermine many of the long-term clean energy policy goals of the Department, Congress, and the Administration. By requiring manufacturers who are already under immense pressure to reduce lead times for distribution transformers – currently 16-plus months – to shift their steel supply to an untested, less flexible, and more expensive source is perilous to our national security, grid resiliency and infrastructure buildout.

## DOE Scaling Factors

NEMA members have a number of concerns about the manner in which DOE has applied scaling factors in the development of this proposed Rule.

DOE made use of the  $\frac{3}{4}$  kVA function to estimate weights, costs, and losses in going from one kVA size to a second one to simplify the engineering analysis. This estimating method is considered generally accurate when considered within a narrow band of power ratings and only when general construction, voltage classes and winding conductor remain the same. This formula is described in detail as to its application in Section 5.2.2 of the TSD from DOE.

The scaling factor (or scaling exponent) has traditionally been assigned a value of 0.75. However, DOE assigned slightly different values to the scaling exponent which are defined in Table 5.2.4 in the TSD (shown below) based on data received in 2013.

**Table 5.2.4 Scaling Exponents by Equipment Class**

| Distribution Transformer Equipment Class                | Scaling Exponent |
|---------------------------------------------------------|------------------|
| 1. Liquid-immersed, medium-voltage, 1-phase             | .76              |
| 2. Liquid-immersed, medium-voltage, 3-phase             | .79              |
| 3. Dry-type, low-voltage, 1-phase                       | .75              |
| 4. Dry-type, low-voltage, 3-phase                       | .74              |
| 5. Dry-type, medium-voltage, 1-phase, 20-45 kV BIL      | .67              |
| 6. Dry-type, medium-voltage, 3-phase, 20-45 kV BIL      | .67              |
| 7. Dry-type, medium-voltage, 1-phase, 46-95 kV BIL      | .67              |
| 8. Dry-type, medium-voltage, 3-phase, 46-95 kV BIL      | .67              |
| 9. Dry-type, medium-voltage, 1-phase, $\geq 96$ kV BIL  | .68              |
| 10. Dry-type, medium-voltage, 3-phase, $\geq 96$ kV BIL | .68              |

DOE applied this formula to designs created by The Transformer Design Program (TRANS) published by the Optimized Program Service, LLC of Strongsville, OH, commonly referred to by transformer engineers as "OPS", thereby creating a massive database of cost, design, and loss information for all different kVA's within their respective equipment classes. It is this data the DOE used for its analysis.

However, as mentioned above, this method is not appropriate for estimating when considering large ranges of transformer kVA ratings.

A NEMA member provided the below analysis of the scaling exponent specifically related to medium voltage dry-type transformers showing wide swings in actual scaling factors computed from real designs. The analysis also demonstrates that only narrow bands of kVA sizes close to the sizes of the representative design units managed to fall within 5% of the results computed by the DOE using their scaling factor. The results of this analysis are summarized below.

#### *Analysis Assumptions*

- All designs are round coils
- All designs based on DOE 2016 efficiencies
- Smaller kVA sizes constrained by realistic wire sizes and UL required construction
- All designs are typical close coupled unit-substations
- Designs are driven off lowest cost outcome
- Equipment Class 6 are barrel wound
- Equipment Class 8 are continuous disk wound HV
- Designs constrained to industry accepted impedances of 5.00% to 5.75%

| Voltage (kV) | BIL (kV) | Equipment Class | Conductor | SF Used by DOE | MATERIAL COST   |                 | Actual Value Within 5% of DOE Calculation |                      |
|--------------|----------|-----------------|-----------|----------------|-----------------|-----------------|-------------------------------------------|----------------------|
|              |          |                 |           |                | Actual Min (SF) | Actual Max (SF) | Scaled from 300 kVA                       | Scaled from 1500 kVA |
| 5            | 30       | 6               | AL        | 0.67           | 0.33            | 1.11            | None                                      | 750, 1000            |
| 15           | 95       | 8               | AL        | 0.67           | 0.14            | 0.98            | None                                      | 1000                 |
| 5            | 30       | 6               | CU        | 0.67           | 0.34            | 1.13            | 150, 225, 500                             | None                 |
| 15           | 95       | 8               | CU        | 0.67           | 0.32            | 0.86            | None                                      | 500, 750, 1000       |

| Voltage (kV) | BIL (kV) | Equipment Class | Conductor | SF Used by DOE | NO LOAD WATTS   |                 | Actual Value Within 5% of DOE Calculation |                       |
|--------------|----------|-----------------|-----------|----------------|-----------------|-----------------|-------------------------------------------|-----------------------|
|              |          |                 |           |                | Actual Min (SF) | Actual Max (SF) | Scaled from 300 kVA                       | Scaled from 1500 kVA  |
| 5            | 30       | 6               | AL        | 0.67           | 0.33            | 0.88            | 225, 500                                  | 750, 1000, 2000, 2500 |
| 15           | 95       | 8               | AL        | 0.67           | 0.37            | 0.86            | 150, 225                                  | 1000, 2000, 2500      |

| Voltage (kV) | BIL (kV) | Equipment Class | Conductor | SF Used by DOE | FULL LOAD WATTS |                 | Actual Value Within 5% of DOE Calculation |                       |
|--------------|----------|-----------------|-----------|----------------|-----------------|-----------------|-------------------------------------------|-----------------------|
|              |          |                 |           |                | Actual Min (SF) | Actual Max (SF) | Scaled from 300 kVA                       | Scaled from 1500 kVA  |
| 5            | 30       | 6               | AL        | 0.67           | 0.51            | 0.88            | 500                                       | 750, 1000, 2000, 2500 |
| 15           | 95       | 8               | AL        | 0.67           | 0.54            | 1.02            | 150, 225, 500                             | 750, 1000, 2000, 2500 |

*Table 1: Scaling factor analysis based on current 2016 efficiency requirements for medium-voltage distribution transformers.*

Note: Scaling factors / exponents were computed based on actual cost and loss information for each kVA size relative to the 300 kVA for the 15 to 500 kVA range and relative to the 1500 kVA in the 750 to 2500 kVA range.

Actual scaling factors can be seen to be relatively accurate when considering kVA sizes relatively close to the representative designs of 300 and 1500 kVA in Equipment classes 6 and 8. Scaling factors are seen to increase with kVA from as low as 0.14 to as high as 1.02. The reasons for this are primarily design constraints on available wire sizes, maintaining impedances in the 5.00% to 5.75% range and specific construction requirements for Underwriter Laboratory requirements. Also, note in the smaller kVA sizes, small wires become very expensive and difficult to use and greatly inflate the prices relative to the kVA size causing a skew in the cost curve. DOE recognized this in the 2013 rulemaking and skewed the efficiency increases to be smaller or zero for the lower kVA's. The 2022 NOPR makes no similar adjustments. The DOE has used OPS software over multiple voltage classes and efficiencies and the scaling factor methodology was used to derive data for the other kVA sizes.

Another limitation to using the scaling factor is the effect of stray and eddy losses on efficiency performance:

- Higher voltage classes have much lower space factor of conductors in the core window because of the need for thicker insulations.
- Eddy current losses within a winding vary as the 4<sup>th</sup> power of conductor thicknesses and need to be included in scaling but have not been.
- Higher efficiencies require much lower current densities that result in thicker conductors and result in much higher eddy losses.
- Higher currents also result in higher stray losses associated with induced losses from current flowing in leads and buses in the core clamps and tanks. The DOE scaling has ignored this.

Another concern is kVA sizes greater than 2000 kVA with low output voltages call for efficiencies that in some cases cannot be reached with GOES and require the use of copper to lower conductor losses to meet the higher efficiency levels. Designs using GOES to meet the proposed NOPR efficiencies have been shown to force flux densities down to 10 kG or below to lower core losses enough to meet the

required efficiency levels. Practical and more realistic flux densities are typically in the 14 to 15 kG range. Flux density levels being forced into the 10 kG range are a clear indication that the design limits for using GOES are at or beyond their technical and economic feasibility. As transformer kVA's increase, lower secondary voltages cause significant increases in buss and lead losses particularly for transformers having 208Y/120 secondary connections. These higher losses in turn constrain no-load (core) losses to be even lower which is why the induction levels are so low to make the designs work. Medium voltage liquid and dry type unit weight increases of 50% generally result in 15% taller, wider, and deeper units compared to those designed to meet the 2016 DOE rule. Sensitive installation locations are an issue. Tank diameters and/or tank heights increases of 15% or more will create new logistical challenges.

Low voltage dry type transformer weights, when constructed with GOES, increase up to 250%, as does cost when designs were possible. However, proposed efficiencies in the NOPR are either impossible or impractical using GOES for many designs, especially in the higher kVA ranges as is evidenced by the DOE's own scatter plots for RU6, RU7 and RU8.

Indoor power modules (lineups) with efficiency levels optimized at 35% load result in larger footprint designs which will complicate these installations where space is at a premium. Furthermore, transformers may even operate less efficiently where average loads are well above the 35% levels.

Significantly higher efficiency levels drive impedance levels lower especially when using GOES steel. Maintaining impedance levels above 4.00% and preferably above 5.00% to prevent excessive fault currents becomes very difficult to maintain. This is a problem when it comes to designing a power system and choosing circuit breakers or fuses which are capable of handling the higher fault currents due to lower transformer impedances in low voltage distribution branch circuits.

## **Section VII. E. *Issues on Which DOE Seeks Comment***

In Appendix A, NEMA Transformer Products Section member companies offer responses to the specific questions posed by the Department in the NOPR.

It is with a considerable sense of frustration that we submit these comments as they would be more detailed and better reflect our full collective view had industry been afforded more time to develop them. While the two additional weeks added to the comment period were somewhat helpful, they were insufficient and offered before NEMA could add its voice to the chorus of organizations requesting more time. Given the depth of information sought by the Department and the technical complexities of the subject matter, NEMA members needed a minimum of 180 days to fully address the Department's questions and data requests. Nevertheless, we appreciate the opportunity, albeit limited, and remain available to answer additional questions.

For all the reasons we present here, we request that the Department issue a Notice of Proposed Determination indicating that energy conservation standards for distribution transformers do not need to be amended because more stringent standards are not economically justified nor in the national interest at this time.

Sincerely,



Alex Baker  
Director, Regulatory Affairs  
National Electrical Manufacturers Association

## Appendix A

### Section VII. E. *Issues on Which DOE Seeks Comment*

1) DOE requests comment on the proposed amendment to the definition of drive (isolation) transformer. DOE requests comment on its tentative determination that voltage ratings of 208Y/120 and 480Y/277 indicate a design for use in general purpose applications. DOE also requests comment on other voltage ratings or other characteristics that would indicate a design for use in general purpose applications.

NEMA members agree that voltage ratings are a poor measure to capture these distinctions.

2) DOE requests comment on its proposed amendment to the definition of “special-impedance transformer” and whether it provides sufficient clarity as to how to treat the normal impedance ranges for non-standard kVA distribution transformers.

NEMA members recommend that kVA be specified in ranges. The normal impedance range for each kVA rating for liquid-immersed and dry-type transformers is show below in Tables 1 and 2, respectively. We offer these tables as recommended replacements for the Tables 1 and 2 proposed in the NOPR definition of *special-impedance transformer*. Addressing kVA ratings not appearing in the table, the new tables recommended below supply the normal ranges for IZ for all units within scope.

| Single-Phase  |               | Three-Phase    |               |
|---------------|---------------|----------------|---------------|
| kVA           | Impedance (%) | kVA            | Impedance (%) |
| 10.0 – 49.9   | 1.0 – 4.5     | 15.0 – 74.9    | 1.0 – 4.5     |
| 50.0 – 249.9  | 1.5 – 4.5     | 75.0 – 112.4   | 1.0 – 5.0     |
| 250.0 – 499.9 | 1.5 – 6.0     | 112.5 – 499.9  | 1.2 – 6.0     |
| 500.0 – 666.9 | 1.5 – 7.0     | 500.0 – 749.9  | 1.5 – 7.0     |
| 667.0 – 833.0 | 5.0 – 7.5     | 750.0 – 5000.0 | 5.0 – 7.5     |

*Table 1: For liquid-immersed distribution transformers*



We note that step-up is not mentioned in the main definition but is included in the LVDT sub-definition. This should be corrected. We recommend the additions underlined below.

...

Regarding DOE's proposed definition, we believe it is unnecessary to set proposed features (1) and (2) as a rule for the definition, since some utilities have been using 65 °C as temperature rise rating. Additionally, on proposed feature (4) we would also recommend adding that the unit can also have surface treatment for corrosion resistance capabilities. With the above comments, we would amend and recommend the following changes to the definition, with deletions in ~~strikeout~~ and additions underlined:

*"Submersible Distribution Transformer means a liquid-immersed distribution transformer, so constructed as to be successfully operable when fully submerged in water including the following features: (1) is rated for a temperature rise of 55°C has sealed tank construction; (2) has insulation rated for a temperature rise of 65°C; (3) has sealed tank construction; and (4) has the tank, cover, and all external appurtenances made of corrosion-resistant material or with appropriate corrosion resistance surface treatment to induce the components surface to be corrosion resistant; and (3) is designed for installation in an underground vault."*

The following points affect the design and limit typical solutions to increasing efficiency:

Submersible transformers are usually installed in vaults, with very strict dimensional requirements, limiting the options to increase the design efficiency.

While operating submerged, the thermal efficiency of submersible transformers drops. Dirty water and debris can negatively impact the effective heat transfer to external surfaces, limiting options to further increase efficiency of such units.

Corrosion resistance usually denotes that this type of transformer features more robust construction regarding tank wall thickness, radiator thickness and surface treatments. All of these decrease the thermal efficiency of such units and affect their capability to regulate transformer operating temperatures and reduce associated losses. While increasing the efficiency would reduce losses and thermal requirements, usually the dimensional limits of existing vaults serve as the primary the limiting factor.

**12) DOE requests comment and data as to the impact that submersible characteristics have on distribution transformer efficiency.**

Given the project-specific impacts of distribution transformer submersion, it is not possible for manufacturers to provide such data. We recommend the Department consult electric utilities for such data.

13) DOE requests data on the difference in load loss by kVA for distribution transformers with multiple-voltage ratings and a voltage ratio other than 2:1.

Due to the myriad ways distribution transformers can be constructed, and that different voltage ratios would necessarily lead to different design philosophies, such data would be exceedingly laborious for industry to develop. NEMA members request clarification on what question(s) the Department seeks to answer.

14) DOE request data on the number of shipments for each equipment class of distribution transformers with multi-voltage ratios other than 2:1.

NEMA members lack data to provide to the Department, however we believe the equipment in question represents less than 2% of the overall distribution transformer market.



(1) Regarding the range of inrush current:

The graph shows the relationship between current ( $I$ ) and time ( $t$ ). The vertical axis is labeled  $t$  and the horizontal axis is labeled  $I$ . A green shaded region represents the 'Thermal tripping limits', which is a curve that decreases as current increases. A pink shaded region represents the 'Electromagnetic tripping limits', which is a vertical band between 'min.' and 'max.' current values. A red dot labeled 'Max Inrush' is located within the pink region.

(2); (3); and (4): please see reply in question 19.

- the potential inrush
- the coil-winding geometry, i.e., length and diameter of coils
- the core configuration
- number of turns in the energized winding

- Inserting resistance during energization of a transformer, also known as soft start, needs to be incorporated in the static transfer switch (STS) system for data center applications but would need to be added into the breaker or fusible safety switch on other applications.





**35) DOE requests comment on its assumed TOC adoption rate of 10 percent. Specifically, DOE requests comment on the TOC rate suggested by NEMA, that between 15 and 20 percent of 3-phase liquid-immersed distribution transformers are purchased using TOC, and that 40 percent of 1-phase liquid-immersed distribution transformers are purchased using TOC. DOE notes, that it is seeking data related to concluded sales based on lowest TOC in the strictest sense, excluding those transformers sold using band of equivalents (see the section on band of equivalents, above)**

The percentage of transformers currently being purchased using TOC is estimated to be lower than 10% for both single-phase and three-phase transformers. This is the result of implementation of DOE's current minimum efficiency levels (April 2013 regulation) as the TOC formula became less relevant when defining the most cost competitive transformer design option. Most customers are purchasing transformers based on lowest first cost that meet the current DOE-mandated efficiency levels.

**36) DOE requests comment on the fraction of distribution transformers purchased by customers using the BOE methodology. DOE notes, that it is seeking data related to concluded sales based on lowest BOE in the strictest sense, excluding those transformers sold using total owning costs.**

Band of equivalence (BOE) is generally not used for low- or medium-voltage dry-type transformer purchases.

**37) DOE request comment if the rates of TOC or BOE vary by transformer capacity or number of phases. Further, DOE seeks the fraction of distribution transformer sales using either method into the different regions in order to capture the believed relationship between higher electricity costs and purchase evaluation behavior.**

TOC A/B factor values do not vary by transformer capacity or number of phases. Most utilities who use TOC methods also apply a band of equivalency, ranging from 3-10% of the TOC, where the lowest first cost transformer in the band is purchased.

**40) DOE request the average extension of distribution transformer service life that can be achieved through rebuilding. Additionally, DOE requests comment on the fraction of transformer that are repaired by their original purchasing entity and returned to service, thereby extending the transformer's service lifetime beyond the estimated lifetimes of 32 years with a maximum of 60 years.**

To more fully answer this question NEMA members request the Department's definition of 'rebuilding'. Rebuilding, as we understand it, does not typically occur with liquid-filled distribution transformers. When rebuilding is undertaken, it is typically a consequence of equipment failure unrelated to end-of-life. To our knowledge, no one is rebuilding low-voltage distribution transformers. So-called rewind shops are wholly separate entities from distribution transformer manufacturers.

**41) DOE requests comment on which liquid-immersed distribution transformers capacities are typically replaced with MVDT. DOE further requests data that would indicate a trend in these substitutions. DOE further requests data that would help it determine which types of customers are preforming these substitutions, e.g., industrial customers, inverter [sic] owned utilities, MUNIs, etc.**

This is not a typical replacement. These two types of distribution transformers coexist in the market.

**42) In response to NEMA's comment DOE requests data to inform a shift in the capacity distribution to larger capacity distribution transformers. Additionally, DOE requests information on the extent that this increasing trend in capacity would affect all types of distribution transformers, or only medium-voltage distribution transformers.**

Roughly 15% of the low voltage commercial market is increasing their distribution capacity sizes, going from 500 kVA to 1000 or 1500 kVA.

43) DOE projected the energy savings, operating cost savings, product costs, and NPV of consumer benefits over the lifetime of distribution transformers sold from 2027 through 2056. Given the extremely durable nature of distribution transformers, this creates an analytical timeframe from 2027 through 2115. DOE seeks comment on the current analytical timeline, and potential alternative analytical timeframes.

NEMA considers that the current estimation of transformer lifetime of 32 years is adequate. Although it is recognized that distribution transformers have an extremely durable nature, other factors that might affect the lifetime should be considered, such as transformer replacements due to potentially higher rates of load growth due to increased electrification initiatives.

**44) DOE requests comment on its assumption that including a rebound effect is inappropriate for distribution transformers.**

We understand that the Department defines the rebound effect as “an increase in utilization of the equipment due to the increase in efficiency and its lower operating cost” (NOPR section IV.H.2). NEMA members agree with the Department’s conclusion that such an effect need not be incorporated into its analyses.

**45) DOE requests comment on the mean PUL applied to distribution transformers owned and operated by utilities serving low customer populations.**

For liquid-filled transformers, in these instances NEMA members estimate PUL would typically be 10% of RMS-equivalent nameplate rating.

**48) DOE requests comment on the estimated potential domestic employment impacts on distribution transformer manufacturers presented in this NOPR.**

The Rule as drafted would require intensive capital expenditures by any company wishing to remain viable in the distribution transformer market in the United States. Such expenditures would most likely come with negative impacts on employment. With the Rule in force, core manufacturing is likely to shift from in-house to outsourcing, which could shift those jobs overseas. While roughly 80% of low voltage dry-type are already manufactured in Mexico or India, medium voltage dry-type products, including their cores, are still predominantly produced domestically. The Department has the opportunity to preserve this

domestic manufacturing base. Should the Department elect to set performance requirements effectively mandating amorphous steel cores, small domestic manufacturers of distribution transformers would likely cease operations as they would have no choice but to outsource cores from a single domestic amorphous core manufacturer enjoying a monopolistic hold on the market.

**49) DOE requests comment on the potential availability of either amorphous steel, grain-oriented electrical steel, or any other materials that may be needed to meet any of the analyzed energy conservation standards in this rulemaking. More specifically, DOE requests comment on steel manufacturers' ability to increase supply of amorphous steel in reaction to increased demand for amorphous steel as a result of increased energy conservation standards for distribution transformers.**

NEMA members note that the scale-up of amorphous steel production to provide an additional 70,000 metric tons annually (verbally stated by a Metglas, Inc. representative on the Department's 16 February 2023 webinar) would be insufficient to support the new distribution transformer market that would be created by the proposed Rule.

It is imprudent for the Department of Energy to impose a new energy conservation standard requiring market capacity that does not yet exist, indeed, to impose requirements that rely on an entirely speculative supply of amorphous steel that does not exist. Instead, NEMA members encourage the Department to consider implementing another rulemaking after the proposed scaling up has occurred.